

MOST COMMON PARK VIOLATIONS

- **Lots Not Identified**
- **Exposed Live Electrical Parts**
- **Miscellaneous Park Plumbing**
- **Electrical Equipment Not Approved for Wet Location**
- **Utility Service Equipment Subject to Vehicle Damage**
- **Gas Meter Not Properly Supported**
- **Garbage, Rubbish, Combustibles**
- **Drain Inlet Open, No Cap**

MOST COMMON RESIDENT VIOLATIONS

- **Garbage, Rubbish, Combustible Material**
- **Stairs Handrail Unsound**
- **Faulty Weather Protection**
- **Stairs No Handrail**
- **Missing, Damaged, Unanchored Awning/Carport Supports**
- **Extension Cord for Permanent Wiring**
- **Stairs Unsound**
- **Storage Cabinet Constructed Less than 3' Lot Line**
- **Appliances Outside**
- **Stairs and Landing Unsound**